

To: Deltoral, Miguel[deltoral.miguel@epa.gov]
From: Suero, Maryann
Sent: Fri 9/4/2015 12:57:45 PM
Subject: RE: FYI / Flint Journal : Lead leaches into 'very corrosive' Flint, Michigan, drinking water, researchers say

Thanks Miguel!

From: Deltoral, Miguel
Sent: Friday, September 04, 2015 7:54 AM
To: Suero, Maryann; Harris, Kimberly; Poy, Thomas; Walts, Alan; Klevs, Mardi; Master, Edward; Singer, Joshua; Lasky, Lara; Porter, Andrea
Subject: Re: FYI / Flint Journal : Lead leaches into 'very corrosive' Flint, Michigan, drinking water, researchers say

The sampling project is ongoing. A summary of the results from samples analyzed so far are on the following website:

<http://flintwaterstudy.org/information-for-flint-residents/results-for-citizen-testing-for-lead-300-kits/>

These sample results are from residents' homes. Basically anyone that wants to sample their drinking water, so they include homes that are high risk and homes that are not. The city of flint estimates that they have about 15,000 lead service lines. Based on information from one of the companies in flint that replaces service lines, the lead portion of the service line is usually only on the utility side, from the water main to the property line, but they have seen some lead service lines that go from the water main all the way into the home as well.

Miguel A. Del Toral

Regulations Manager
U.S. EPA R5 GWDWB
77 West Jackson Blvd, (WG-15J)
Chicago, IL 60604
Phone: (312) 886-5253

From: Suero, Maryann

Sent: Thursday, September 3, 2015 08:38 AM

To: Deltoral, Miguel; Harris, Kimberly; Poy, Thomas; Walts, Alan; Klevs, Mardi; Master, Edward; Singer, Joshua; Lasky, Lara

Subject: FYI / Flint Journal : Lead leaches into 'very corrosive' Flint, Michigan, drinking water, researchers say

(I couldn't find where Virginia Tech reported the lead levels from Flint DW, so if anyone does find it, please share...thanks!)

Lead leaches into 'very corrosive' Flint, Michigan, drinking water, researchers say.

Flint drinking water is "very corrosive" and "causing lead contamination in homes," researchers from Virginia Tech University reported online Wednesday, Sept. 2.

Flint Journal, Michigan.

http://www.mlive.com/news/flint/index.ssf/2015/09/new_testing_shows_flint_water.html